

Department of Engineering  
Tim Bryan, P.E., County Engineer

3137 South Liberty Street, Canton, MS 39046  
Office (601) 790-2525 FAX (601) 859-3430

**MEMORANDUM**

March 2, 2022

To: Sheila Jones, Supervisor, District I  
Trey Baxter, Supervisor, District II  
Gerald Steen, Supervisor, District III  
Karl Banks, Supervisor, District IV  
Paul Griffin, Supervisor, District V

From: Tim Bryan, P.E., PTOE  
County Engineer

Re: AT&T Utility Permit  
Stribling Road and Catlett Road

The Engineering Department recommends approval of the permit application for AT&T to directionally bore 3500' of fiber cable from Caroline Blvd. and Stribling Road along Stribling Road then along Catlett Road South to Falls Crossing.



## PERMIT APPLICATION FOR THE CONSTRUCTION OR ADJUSTMENT OF A UTILITY WITHIN COUNTY ROAD RIGHT-OF-WAY

Utility Information: Utility Name: \_\_\_\_\_

Address: \_\_\_\_\_ City/State/Zip: \_\_\_\_\_

Contact Person: \_\_\_\_\_ Contact's Phone: \_\_\_\_\_

Project Information: County Road Name: \_\_\_\_\_

(If located within more than one road right-of-way, use Appendix 1 for additional descriptions)

Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_

Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_

Description of Work: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Check Box if Appendix 1 is to be included as a part of this Application

Whereas the above stated Utility makes application to the **Madison County Board of Supervisors** for a Construction Permit. Attached hereto are drawings and plans for the construction of the above facilities located within Madison County owned public rights-of-way. Once stamped by the Madison County Engineering Department, these plans shall not be changed or altered without written approval of the County Engineer, or his representative. A copy of the approved permit and plans shall be on-site at all times during construction.

The Applicant Utility shall comply with all policies, procedures and construction practices as outlined in *A Policy for The Accommodation of Utility Facilities within the Right-of-Way of all Public County Roads* (hereinafter referred to as the "Policy"), as adopted on November 1, 2005, by the **Madison County Board of Supervisors**, and which is hereby made a part of this Application Agreement.

If facilities are to be located within the Rights-of-Way of the County-Federal or State Aid System, Applicant Utility also agrees to comply with applicable provisions of *S.O.P. No. SA II-2-8, Accommodation of Utilities on Rights-of-Way*, issued by the State Aid Engineer and dated July 1, 2005.

The Applicant Utility understands and agrees that, except as herein granted, no right, title, claim, or easement to said road right-of-way is granted by the issuance of this permit. If this Utility is listed in the general provisions of the Policy, it will be adjusted to comply with same without cost to the County, unless the variance from the Policy has been approved by the granting of the Permit pursuant to this Application.

The Applicant Utility further understands that the Utility's engineering, plant, or other personnel will be responsible for the staking and construction supervision of the work set out above and as shown on the attached plans. If work impacts traffic in any way, the appropriate traffic control shall be installed per the *Manual of Uniform Traffic Control Devices*, Latest Edition.

The Applicant Utility understands that the County Engineer, or his representative, may issue a Stop Work Order at any time if it is deemed that site conditions are not suitable for construction or if any of the requirements of this permit are not being met.

Many County Roads have variable Rights-of-Way and/or no Right-of-Way at all and are maintained under a Prescriptive Easement. It is the sole responsibility of the Applicant Utility to verify the existence and limits of public rights-of-way. If none exists, it is the

responsibility of the Applicant Utility to acquire an easement for their Facilities from the applicable property owner(s). Madison County in no way verifies the limits of Right-of-Way as shown on the permit application.

The Applicant Utility shall be responsible for all future maintenance and repair of the facilities installed under this permit. The Applicant Utility shall make future adjustments to, or relocate, the facilities located within road or highway right-of-way when required for road or highway widening or other road or highway construction at no cost to Madison County. The Applicant Utility shall relocate said utilities within sixty (60) days of notification by County by registered mail, return receipt requested, unless otherwise designated by the County Engineer. Further, any maintenance, repair, or construction shall be done in such a manner as to occasion no unreasonable interference with the normal flow and safety to traffic and at the expense of the utility company. When reasonable care has been taken to locate said utility facilities within the right-of-way, the Applicant Utility understands that any damages caused by routine maintenance and construction by County forces shall be borne by the Applicant Utility.

The Applicant Utility further agrees to indemnify and hold Madison County harmless for any and all claims, accidents, damages, liabilities and expenses occasioned wholly, or in part, by any act or omission of applicant, its agents or employees. In case County shall, without fault on its own part, be made a party to any litigation commenced by or against applicant, then applicant shall protect and hold County harmless, and shall pay all costs, expenses and reasonable attorney's fees incurred or paid by County in connection with said litigation.

All underground facilities shall be installed at a depth equal to or greater than 48" below the lowest adjacent grade.

All pipes carrying liquid shall be encased under County maintained roads.

WITNESS the signature of the Applicant this the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

By: \_\_\_\_\_  
(Applicant Signature)

Title: \_\_\_\_\_

**Note:** *Applicant must be an employee of the Utility named in this application. The Madison County Board of Supervisors will not recognize a Contractor, Subcontractor, Agent, or Consulting Engineer as the Applicant. Utility Company shall be fully responsible for all work performed under this application.*

I, or my authorized representative, have reviewed this application and determined that the drawing, sketches, and plans submitted by the Applicant meet the requirements of *A Policy for The Accommodation of Utility Facilities within the Right-of-Way of all Public County Roads.*

By: \_\_\_\_\_  
**Tim Bryan, P.E.**  
**County Engineer**

AGREED TO AND APPROVED BY:

\_\_\_\_\_  
**Madison County Board President**

Date: \_\_\_\_\_

ENTERED INTO THE MINUTES OF THE BOARD OF SUPERVISORS OF MADISON COUNTY, MISSISSIPPI ON THIS \_\_\_\_\_ DAY OF \_\_\_\_\_, 20\_\_\_\_\_.

**Appendix 1**

County Road Name: \_\_\_\_\_  
Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_  
Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_  
Description of Work: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


County Road Name: \_\_\_\_\_  
Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_  
Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_  
Description of Work: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

County Road Name: \_\_\_\_\_  
Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_  
Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_  
Description of Work: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

County Road Name: \_\_\_\_\_  
Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_  
Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_  
Description of Work: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

County Road Name: \_\_\_\_\_  
Beginning Location: \_\_\_\_\_ Ending Location: \_\_\_\_\_  
Length of Project: \_\_\_\_\_ Section: \_\_\_\_\_ Township: \_\_\_\_\_ Range: \_\_\_\_\_  
Description of Work: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Wire Center Name: ma  
 Tax District: 04513  
 Taper Code: 2255ZC  
 County: MADISON  
 Contractor Name: ANN.SWANNER@BYERS.COM  
 State: MS  
 Project Description: PFP:2255ZC,PL 1.5KF FBR & 432 PFP FOR PON SVC @ AUTUMN CREST SUB,PHASE 1-60LU  
 Category: FEEDER  
 Scope: FIBER





NOTE:FIBER DISTRIBUTION  
 WILL BE PLACED  
 ON CFAS #A0286NX

PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 1	OF 7

4

FID #56828414  
(2017) 845C 1917'  
SR-5BQ2MT-144

OLT2255A, 3-4 NC  
OLT2255A, 13-14 NC  
(J, 5-6) <A026J8M> OLT2255A, 33-34  
J, 7-8 NC  
F, 9-144 NC



5BQ2MT-144  
2013 DBOR

CONNECTOR  
FID #57480058

See DWG #6  
Bore Detail "A"

FID #56828396


(2017) 845C 2471'  
SR-5BQ2MT-144

OLT2255A, 3-4 NC  
OLT2255A, 13-14 NC  
(J, 5-6) <A026J8M> OLT2255A, 33-34  
OLT2255A, 41-41 NC  
F, 8-144 NC

STRIBLING RD


FID #56809406  
HH 407 CATLETT RD  
HANDHOLE 30X60 (2017) 845C  
1 X 1 X 1 = 1

NOTE TO CONSTRUCTION:  
PL 144 BUR FBR  
FROM HH IN ROW 30' N OF  
STRIBLING RD C/L TO CATLETT RD,  
TO 20' E OF C/L, AND 10' E OF EOP.  
TURN S AND CONTINUE 144 BUR FBR  
AT 20' E OF C/L, 10' E OF EOP, 5' INSIDE ROW.  
BURY AT 36" MIN. DEPTH.



SEE DWG #3

PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 2 OF 7	



406




**CONST NOTE:**  
 CONTINUE 144 BUR FBR  
 AT 20' E OF C/L,  
 10' E OF EOP,  
 5' INSIDE ROW.  
 BURY AT 36" MIN. DEPTH.

390

PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 3 OF 7	

4



FID #131743490  
 (PPA) 845C 1993'  
 5BQ2MT-144  
 OLT2255A, 41-41  
 D, 2-144


CONST NOTE:  
 CONTINUE 144 BUR FBR  
 AT 20' E OF C/L,  
 10' E OF EOP,  
 5' INSIDE ROW.  
 BURY AT 36" MIN. DEPTH.

PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 4 OF 7	



SEE DWG #4

CONST NOTE:  
CONTINUE 144 BUR FBR  
IN SW DIRECTION ALONG FALL'S XING,  
20' SE OF C/L, 10' SE OF EOP,  
WITHIN THE COMMON AREA U/E.  
BURY AT 36" MIN. DEPTH.



**2** FID #13173490  
(PPA) 845C 1993'  
5BQ2MT-144  
OLT2255A, 41-41  
D, 2-144

FIB CONNECTOR  
FID #131808817  
F1 845C SPL  
F2 845C SPL  
STORE TAIL  
IN SPL CASE  
& GROUND

See DWG #6  
Bore Detail "D"

See DWG #7  
HH Detail

EXISTING PFP/SPL  
SHOWN FOR  
REFERENCE ONLY  
TO EXISTING HH.

FIBER DISTRIBUTION  
TO BE PLACED ON  
CFAS A0286NX

**3** FID #131598940  
(PPA) 845C 100'  
FBRTLTS-096  
OLT2255A, 41-41  
D, 2-96


**5** HH FID #56808581  
HANDHOLE 30X60 (2013) 845C  
1 X 1 X 1 = 1

**11** FID #131744746  
(PPA) 845C 100'  
FBRTLTS-432  
PON2255ZC, 1-432


**12** FID #131744577  
MDSNMSESPFP  
F 100.2 FALLS XING  
BJCNDM432-100ST (PPA) 845C  
IN SPT2255ZC, 1-64  
OUT PON2255ZC, 1-432

**13** FID #131744230  
MDSNMDESSPT  
F 100.2 FALLS XING  
SPLSCAPC1X64CIL (PPA) 845C  
IN OLT2255A, 41-41  
1X64 SPT2255ZC, 1-64


PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022	
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses	
PRIMARY ENGR.: MIZELL, DAVID R.			
ENGR. ID: DM5301		PERMIT REQ'D.	N
PHONE #: 6018593307		PRINT 5 OF 7	




PRINT 2  
BORE DETAIL "A"



PRINT 3 & 4  
GRAVEL DRIVEWAY  
BORE DETAIL "B"




PRINT 3  
BORE DETAIL "C"



PRINT 5  
BORE DETAIL "D"

PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 6 OF 7	



PROJECT # <b>A028BXG</b>		DATE SVC REQ'D 05/10/2022
NPANNX 601856	GEO LOC 72148	CLLI mdsnmses
PRIMARY ENGR.: MIZELL, DAVID R.		
ENGR. ID: DM5301	PERMIT REQ'D.	N
PHONE #: 6018593307	PRINT 7 OF 7	