



MADISON COUNTY BOARD OF SUPERVISORS

125 West North Street • Post Office Box 608
Canton, Mississippi 39046
601-855-5500 • Facsimile 601-855-5759
www.madison-co.com

March 6, 2025

WHEREAS, the undersigned has been advised by the Director of Buildings and Grounds and the Madison County Sheriff's Office that the exhaust fans in a pod at the Madison County Detention Center are inoperable because of an electrical issue thereby creating a potentially dangerous situation for Madison County employees.

THEREFORE, under the powers vested in me by the Madison County Board of Supervisors and Miss. Code Ann. §31-7-1 et seq., I, Greg Higginbotham, County Administrator and Madison County Board of Supervisors' officially named designee, do hereby declare an emergency exists concerning the safety and welfare of Madison County employees. This declaration shall only be applicable to expenses incurred by the Madison County Sheriff's Office and the Madison County Board of Supervisors related to electrical issues impacting the exhaust fans.



Greg Higginbotham, County Administrator

- Emergency Issue -



3180 Utica Ave
Jackson, MS 39209
(601) 531-8809
service@specialtyheat.com

Invoice

DATE	03/19/2025
INVOICE#	250436
TERMS	NET 30
DUE DATE	04/18/2025

BILL TO
Madison County Board of Supervisors 125 W North St Canton Mississippi 39046-3757 (601) 842-9661

SERVICE LOCATION
Madison County Detention Center 2935 Highway 51 Canton Mississippi 39046-8665 (662) 763-2263

JOB#	DATE	PO/REF#	DESCRIPTION
250436	03/06/2025		<p>Exhaust fans in an entire pod are tripping off for an unknown reason. Need to inspect.</p> <p>Completion Notes: Arrival to site and was told that none of the exhaust fans on the roof were running.</p> <p>Tracked panels from an and c hall and found two tripped breakers. Shutoff all the fans on the roof and began checking fans to find any burnt fans or anything not working.</p> <p>After checking all the fans found several on a hall not receiving any voltage to the outlets. Found one bent fan for the panel room that was fried and found 3 fans on c hall that were burnt up and need replacing.</p> <p>Called electricians and began a game plans for getting the voltage to the fans that are missing it.</p> <p>Returned 3/7/25 Returned to site and began double checking fans and making sure we didn't miss anything before the electricians got onsite. After they got on site we worked with them to track circuits and game plan for the fans still missing voltage.</p> <p>Returned 3/10/25 Returned onsite and stayed onsite until electricians were successful and got all the fans running that needed voltage to them</p>
Job Charges			Qty Rate Total
Total For Above Work			\$6,230.49
Job Subtotal			\$6,230.49
7% Tax			7.00% \$5.67
Job Total			\$6,236.16

CUSTOMER MESSAGE

Invoice Total:	\$6,236.16
Deposits (-):	\$0.00
Payments (-):	\$0.00
Total Due:	\$6,236.16