

MADISON COUNTY BOARD OF SUPERVISORS

125 West North Street • Post Office Box 608 Canton, Mississippi 39046 601-855-5500 • Facsimile 601-855-5759 www.madison-co.com

WHEREAS, the undersigned has been advised by the Director of Buildings and Grounds that the water meter and surrounding pipe at Sulphur Springs Park was in need of repair to ensure access to water at the park, which also serves as a place of respite in the event of severe weather. Because of the County's statutory duties regarding emergencies, the delay incident to giving the opportunity for competitive bidding would be detrimental to the interest of the County.

THEREFORE, in accordance §31-7-1 et seq. and as the Madison County Board of Supervisors' officially named designee to declare emergencies, I, Greg Higginbotham, do hereby declare an emergency exists concerning the repair of the water meter and surrounding pipes. This declaration shall only be applicable to expenditures incurred by the Madison County Board of Supervisors in repairing the water meter and surrounding pipes.

Greg Higginbotham, County Administrator

Bufkin Mechanical Inc

1888 Main Street, Suite C-262 Madison, MS 39110

AMOUNT DUE	\$3,260.00	
PAYMENT TERMS	Upon receipt	
INVOICE DATE	Feb 14, 2025	
JOB	#81204	

Madison County Board Of Supervisors 146 West Center Street Canton, MS 39046

(601) 842-9661

drew.ridinger@madison-co.com

SERVICE ADDRESS

929 Sulphur Springs Rd Canton, MS 39046

CONTACT US

(601) 898-8100

bufkinmech@gmail.com

Service completed by: Eddie Neese, Tommy Avilez

INVOICE

EN/TA-1 - Feb 14, 2025

Services	amount
14 Plumbing - Plumbing Service	\$330.00
Sulphur Springs Park - Main Health Building	
Call (Drew): Water leak coming out of meter box. Staff checked and said it is on their side.	
 Upon arrival crew met with Terry Bacon (County Staff) and he showed them the leak. Crew pumped out meter box and found water was coming from outside meter box. Hand excavated beside meter box and found another meter box. Turned water off at meter and pumped out other meter box. Found a 2" ball valve that was around 3' deep busted. Crew tried to call Drew and inform him of findings and he did not answer. Crew left him a message to return their call. Crew needed to know if they needed a private utility locator due to this being on private property. Crew would need to excavate and recommended going back with a 2" curb stop instead of a ball valve. 	
14 Plumbing - Equipment - Pump (manual)	\$15.00
14 Plumbing - Travel Fee	\$0.00
* Waived (SB)	

EN/TA-1 subtotal

\$345.00

EN/TA-2 - Apr 07, 2025

Services		amount
14 Plumbing - Plumbing Service		\$1,210.00
 Turned water supply off to park. Pumped water out of meter boxes. Excavated to access leaking 2" valve. Cut out leaking ball valve. Installed new 2" curb stop. Reconnected line with a 2" bolted dresser coupling. Allowed glue adequate time to dry with the temperature being cooler. Slowly turned water back on to property. Meter had stopped spinning. No leaks detected. Packed dirt around pipe and valve. Installed meter box and backfilled area. Dressed area with excavator 		
14 Plumbing - Equipment - Excavator		\$500.00
14 Plumbing - Underground Utility Locating/Marking		\$462.00
14 Plumbing - Equipment - Pump (electric)		\$40.00
15 HVAC - Travel Fee * Waived (SB)		\$0.00
Materials		amount
14 Plumbing - Material CP-8881, K-9602		\$703.00
	EN/TA-2 subtotal	\$2,915.00
	Subtotal	\$3,260.00
	Total Tax	\$0.00
	Tax Exempt (0%)	\$0.00
	Job Total	\$3,260.00
	Amount Due	\$3,260.00

* There is a (1) hour MINIMUM charge for ALL service calls.* Payment balances are due in full upon receipt of invoice.* All balances not paid within (30) days of invoice date are subject to SERVICE CHARGES of 1.5% per month.* Register to receive senior citizen, active
military/veteran, and first responder discounts!* Your business, prompt payment, and referrals are appreciated!
See our Terms & Conditions (https://pro.housecallpro.com/BufkinMechanicalInc/11526/terms)